

Attestation of Conformity

No. 2019-796

Cables for use in construction works Reaction to fire class D_{ca}

Company

OPENET ICS INTERNATIONAL, SL
Ctra. de Rubí, 324 nave-D
Pol. Ind. Can Guitard
08228 Terrassa, Barcelona
Spain

Product description

Screened communication cable (F/UTP) with solid conductors, 4 twisted pairs, LSZH

Product identification

F/UTP CAT6 4P 23AWG LSZH
Part no.: 0809D2

Reaction to fire standards

- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015 and A11:2016
- EN 50399:2011 including amendment A1:2016
- EN 60754-2:2014
- EN 13501-6:2018

Reaction to fire classification

Class D_{ca}-s2,d2,a1

Technical report


T936387, DANAK-19/20738

EC Cabling product ID

7020

This product has undergone a one-time test performed by FORCE Technology and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.

Hørsholm, 2 December 2019



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department